ET- 4-14/1/A Reference No.

Approved Far Bala ₱₱78-04720A00010**89***\$***002**9**45**2*0\$* UNITED STATES GOVERNMENT

TO : Assistant Director for Communications

DATE: 18 May 1953

FROM : Chief, Engineering Division, OC

SUBJECT:

Emergency Power Facilities

25X1A6a

- REFERENCE: (A) Memorandum to Assistant Deputy Director (Administration) from Acting Chief, Logistics, dated 8 May 1953
 - (B) Nemorandum from Commanding Officer, to ABD/A, dated 30 April 1953

25X1A6a

1. The attached correspondence represents the recommendations of this division in supplying emergency power at the languages of this division made a survey of emergency power requirements at that station and made recommendations to the who used them in proparing this request.

25X1A6a

25X1A6a

25X1A6a

25X1A6a

2. The recommendations for emergency power for the do not meet with the approval of this division on the basis of good engineering practices. It appears that a detailed survey of power requirements for this station should be made, as was done in the case of the mendations for emergency power made on the basis of the importance this station assumes in the event of emergency conditions. On the basis of a very preliminary investigation, it appears that the distribution system of should be revised to permit the use of a single emergency power service for the station. This would require a considerable outlay of funds at the present, but future costs of a double generator installation as proposed would exceed these funds many times over.

25X1A6a

25X1A6a

3. The Engineering Division is prepared to undertake the power survey for the survey, it is so desired. To guide such a survey, it would aid immeasurably to have a statement of importance which would govern the extent of the system finally engineered.



25X1A9a

ATTATCHMENTS (2)

